

Certificate of Compliance

Certificate Number **20110228 – EX15769**
Report Reference **EX15769 , 2010 December 30**
Issue Date **2011 February 28**

Page 1 of 1



Issued to: **SAUDI STEEL PIPE CO**

DAMMAM 2ND INDUSTRIAL CITY,
PO BOX 11680
DAMMAM, 31463 SAUDI ARABIA

*This is to certify that
representative samples of*

Metallic Sprinkler Pipe

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8 & 10 in. sizes, and Schedule 30 steel pipe in the 8 and 10 in. sizes.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:


UL Standard for Metallic Sprinkler Pipe For Fire Protection UL 852 Second Edition Latest Revision Date: 2010-07-26

The schedule 30 & 40 steel pipe is thread able and conforms to ANSI B1.20.1

Additional Information:

See UL On-Line Certification Directory at www.UL.com for additional Information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney,
Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd.